


Figure: 28 TAC §34.722(h)



**DO NOT REMOVE BY ORDER OF
TEXAS STATE FIRE MARSHAL**

16	1
17	2
18	3
19	4
20	5
21	6
22	7
23	8
24	9
25	10
26	11
27	12
28	13
29	14
30	15
31	

RED TAG

*Name & Address
of Sprinkler Firm
Phone Number
SCR-Number*


RME's License Number

Printed name of service
person

Signature of authorized
serviceperson /
inspector

JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
2015	2016	2017	2018	2019	2020						

**IMMEDIATELY
REPORT STATUS TO
OWNER AND AHJ
IN WRITING
(within 5 business
days)**



If the system impairments constitute an “emergency” impairment as defined in NFPA 25, attached this red tag to the applicable system riser. An authorized individual may remove this tag after a service tag has been attached indicating the condition has been corrected.

Name of Owner or Occupant

Address

Building No. or Location or System No.

List Emergency Impairments
