

Figure: 28 TAC §34.1302(a)

Citation	Violation	Fine		Citation	Violation	Fine
	License and Registration			34.517(e)	Fixed system not installed or serviced by Type A or EPL	\$2,000.00
6001.152(a)	Branch office registration certificate required	\$1,000.00			Installation and Service	
6001.161(a)	Apprentice permit required	\$500.00		34.517(a)(1)	Portable extinguisher not installed/serviced/maintained IAW manufacturer's instructions	\$50.00- \$500.00
6001.251(a)(1)	No registration certificate (portable)	\$3,000.00		34.517(a)(2)	Service tag not attached upon completion	\$250.00
6001.251(a)(2)	No registration certificate (fixed)	\$3,000.00		34.517(b)(1)	Fixed system not planned/installed/serviced IAW 'manufacturer's Instructions	\$50.00- \$500.00
6001.251(a)(3)	No license	\$3,000.00		34.517(b)(2)	Installation label not affixed to system upon completion	\$250.00
34.510(e)(10)(A)	No C registration for U.S. DOT extinguishers	\$2,000.00		34.517(b)(3)	Installation label not signed and affixed to system by Type A or PL licensee (non pre-engineered)	\$500.00
34.510(e)(10)(B)	No verification of U.S. DOT registration	\$2,000.00		34.517(b)(3)	Licensee who signed label was not at final test (non pre-engineered)	\$500.00
34.510(f)	Registration information not displayed on vehicle	\$250.00		34.517(b)(4)	Service tag not attached after service completion	\$500.00
34.511(f)(1)	Licensee not employed by registered firm	\$2,000.00		34.517(f)	Pre-engineered kitchen system not UL300	\$2,000.00
34.511(f)(3)	Failure to notify SFMO of termination of employee within 14 days	\$250.00		34.517(h)	Fusible link manufacturer date not within 1 year	\$500.00
34.513	Alteration of certificates, licenses, or permits	\$3,000.00		34.517(i)	Actuation cartridge not dated	\$500.00
34.514(a)(5)(b)	Failure to maintain proof of insurance on file at SFMO	\$750.00		34.517(j)	Tamper indicator not dated	\$500.00
	Adopted Standards			34.518(a)	Shop drawings not on file or not given to owner	\$500.00
34.517(a)(1)	Failure to abide by adopted standards or manufacturers requirements for portable extinguishers	\$50.00 - \$500.00		34.518(c)	Shop drawings not signed by EPL	\$500.00
34.517(b)(1)	Failure to abide by adopted standards or manufacturers requirements for fixed extinguishers			34.519(a)	Service tag not completed in detail	\$250.00
	Location and Business Practices			34.520(b)	Service tag not completed each time service is performed	\$500.00
34.510(d)	Failure to maintain business location	\$500.00		34.521(a)	Owner not notified immediately of impaired portable or fixed extinguisher	\$500.00
34.510(e)	Failure to maintain shop	\$50.00- \$500.00		34.521(a)	AHJ not notified within 24 hrs of impaired portable or fixed extinguisher	\$500.00
6001.252(a)(3)	Misrepresentation of goods or services	\$250.00- \$1,000.00		34.521(a)	Written notice to owner; copy of written notice to AHJ within 3 days	\$500.00
34.517(c)	Pre-engineered system not installed or serviced by authorized licensee	\$2,000.00		34.521(a)	Failed to attach red tag to impaired extinguisher	\$500.00
34.517(e)	Fixed system not planned by EPL or professional engineer	\$2,000.00		34.521(a)	Service tag attached to impaired extinguisher	\$1,000.00

34.514(a)(5)(B)		Lapse of Insurance			
Months	Punitive	+	Amount saved	=	Total
0 - 1	\$200	+	\$125	=	Warning Letter
1 - 2	\$500	+	\$250	=	\$750
2 - 3	\$500	+	\$375	=	\$875
3 - 4	\$500	+	\$500	=	\$1,000
4 - 5	\$500	+	\$625	=	\$1,125
5 - 6	\$500	+	\$750	=	\$1,250
6 - 7	\$750	+	\$875	=	\$1,625
7 - 8	\$750	+	\$1,000	=	\$1,750
8 - 9	\$750	+	\$1,125	=	\$1,875
9 - 10	\$750	+	\$1,250	=	\$2,000

10 - 11	\$750	+	\$1,375	=	\$2,125
11 - 12	\$750	+	\$1,500	=	\$2,250