Figure: 28 TAC §34.1302(d)

Code	GENERAL	FINE		Code	PATHWAYS/CORRIDORS OF EGRESS cont	Fine
34.817(m)	**TRASH**, cardboard or high grass within 10 ft of site	$50.00		36.2.5.8	No clear exit path **AROUND CHECKOUT** aisle	$250.00
34.832(12)	Supervisor less than **18 YEARS OLD** (site closed until corrected)	$500.00		7.11.5	Building has **DEAD END CORRIDORS**	$150.00
34.832(12)	Individuals less than **16 YEARS OLD SELLING** Fireworks	$50.00		7.2.1.11.1	Turnstile, ropes or other **DEVICES OBSTRUCT EGRESS**	$150.00
34.817(h)	Operator consuming or under influence of **ALCOHOL**	$500.00			**EXIT DOORS**	
2154.252(c)	Fireworks sold or offered to **CHILDREN** under 16 years old or to an intoxicated or incompetent person	$500.00		7.11.4	Less than **TWO** means of **EGRESS** if room >200 sqft	$500.00
34.817(l)	No off highway **PARKING** provided	$100.00		7.11.1	No **EXIT WITHIN 75** ft of any point in the building	$150.00
34.817(g)	**SMOKING** inside the site	$500.00		7.7.1	Exits do not **TERMINATE** in open space (i.e. blocked)	$150.00
34.817(g)	**SMOKING** outside within 10 feet of site	$250.00		7.2.1.2.3.2	**DOOR OPENINGS** less than 32" wide	$150.00
2154.202(g)	Selling fireworks **OUTSIDE** selling **SEASON**	$250.00 TO $500.00		7.2.1.4.2	Door 'doesn't **SWING OUT** in direction of egress	$250.00
	FIREWORKS STORAGE			7.2.1.3.1	Floor **ELEVATION** change Interior >½ or Exterior door >8"	$100.00
34.832(6)	Stored fireworks in sales area **ACCESSIBLE** to public	$100.00		7.2.1.3.3	**THRESHOLD** at door exceeds ½" in height	$100.00
34.832(7)	Fireworks storage room not **RESTRICTED** to employees only	$100.00		7.11.6	**DOORS** latch or lock not fire or **PANIC HARDWARE**	$1,000.00
34.832(7)	**"NO SMOKING"** signs not posted in storage room	$50.00		7.2.1.5.2	Doors have **KEY LOCKS** on egress side.	$500.00
	STORAGE (and retail sales) OVER 500 CASES			7.2.1.4.1(3)	Ex (a&c) Not **LOCKED OPEN** when occupied	$250.00
34.823(a2)	Not of **SOLID CONSTRUCTION** or sound engineering	Case		7.2.1.4.1(3)	Ex (b) No "This Door To Remain OPEN etc…" **SIGN**	$100.00
34.823(a3)	Electrical does not meet **NATIONAL ELECTRIC CODE**	$25.00 TO $250.00		**Code**	**EXIT DOORS (cont)**	Fine
34.823(a3)	No outside **MASTER ELECTRICAL SWITCH**	$250.00		7.2.1.4.1(3)	Ex (e) No **ONE PANIC** hardware door without a roll-up	$500.00
34.823(a4A)	**LESS 50ft** from inhabited bldg(s) or surface of highways	$500.00			**SIGNS**	
34.823(a4A)	Not in compliance with distances in **TABLE 1** 34.824	$500.00		7.10.1.2.1	Not all exits have **"EXIT" SIGNS**. (if exit not obvious)	$100.00
34.823(a4B)	**WINDOWS** or sunlight on fireworks not diffused	$50.00		7.10.6.1.1	"EXIT" **SIGNS NON-COMPLIANT** with standard	$50.00
34.823(a4C)	**STOVE**, exposed flame or electric heater in storage area	$500.00		7.10.2.1	Missing **DIRECTIONAL SIGNS** to exits (if not apparent)	$50.00
34.823(a4D)	Swing **EXIT DOOR** locked, not marked or obstructed	$250.00		7.10.6.2.1	Directional **SIGNS NON-COMPLIANT** with standard	$50.00
34.823(a4E)	No Class A **EXTINGUISHER** for each 1000 sqft of floor	$100.00		7.10.8.3	Missing **"NO EXIT"** sign on doors that could be mistaken	$250.00
34.823(a4F)	Brush, dry grass, leaves or **COMBUSTIBLES** within 10ft	$100.00		34.817(g)	**"NO SMOKING"** sign not posted **OUTSIDE** entrance doors	$100.00
34.823(a4G)	Missing **"NO SMOKING"** signs. (4" letters)	$100.00		34.817(g)	**"NO SMOKING"** sign not posted **INSIDE** entrance doors	$100.00
34.823(a5)	No fence, **SECURITY ALARM** or 24 hr. personnel on site	$500.00		34.817(g)	**"NO SMOKING"** sign not posted **several location** inside	$100.00
34.823(a6)	Class I **COMBUSTIBLES** (gasoline) less 100 ft from bldg	$100.00		34.817(g)	**"NO SMOKING"** sign lettering less than 4 inches high	$50.00
34.823(a6)	**CLASS I** dispensing or vents less than 100 ft from bldg (site closed)	$500.00			**EMERGENCY LIGHTING** (if over 3000 sq.ft.)	
34.823(b1)	No **SUPERVISOR** at least 18 years old on duty (site closed until corrected)	$500.00		36.2.9	No **EMERGENCY LIGHTING** provided	$500.00
34.832(3A)	< 60ft from **INHABITED** bldg. (w/o permit before 11-18-02)	$500.00		7.8.1.3	Emergency lighting doesn't **ILLUMINATE** paths of egress	$250.00
34.832(3B)	< 30ft from **PROPERTY** line (w/o permit before 11-18-02)	$250.00		7.9.2.1	Emergency lighting **DURATION** is less than **1½ hrs**	$250.00
34.832(3C)	Does not comply with **TABLE 1** or have fire sprinklers	$500.00		7.9.3.1.1	No **RECORD** of emergency lighting inspection **& TEST**	$100.00
	PATHWAYS/CORRIDORS OF EGRESS				**STRUCTURE**	
36.2.5.5	Means of **EGRESS/AISLES** less than **36 inches**	$150.00		34.832(1)	Building is not FREE STANDING or durable	Case
36.2.5.10	Means of egress < **36" + CART LENGTH** (if using carts)	$150.00		34.832(1)	Mezzanine or 2nd STORY accessible to the public	$150.00
34.817(e)	Path to exit door **OBSTRUCTED**	$250.00		34.832(1)	Selling from a TENT, boat, or mobile vehicle (site closed)	$500.00

7.1.10.1	Egress not **CONTINUALLY FREE** of obstructions	$150.00		34.817(k)	Bldg. single or multi-family RESIDENTIAL STRUCTURE (site closed)	$500.00
Code	**STRUCTURE cont**	**Fine**		**Code**	**STAIRS**	**Fine**
34.832(1)	Sales area Multi-Use (other business) or MULTI-TENANT (site closed)	$500.00		7.2.2.2.1	RISER not 4"-7" or TREADS less than 11" wide	$100.00
34.832(18)	Sales area >2500 sqft with ave. CEILING HEIGHT < 12 ft	$500.00		7.2.2.2.1.2	Less than 36" WIDE or < 56" wide if occupancy over 2000	$100.00
34.832(10)	Stored behind glass with impinging direct SUNLIGHT	$50.00		7.2.2.3.3.1	Stairs treads not SOLID	$100.00
34.832(14)	No outside MASTER electrical switch	$100.00		7.2.2.4.1.1	No HANDRAILS 34" to 38" high provided	$100.00
9.1.2	Electrical WIRING and equipment APPEAR HAZARDOUS	$25.00 TO $250.00		7.1.8	Open stairs over 30" rise without a GUARD RAIL	$100.00
	INTERIOR				**STAIR LANDINGS**	
34.832(5)	Inadequate PREVENTION of customers handling fwks	$100.00		7.2.2.3.2.1	No LANDING at door opening	$100.00
34.832(5)	RESTRAINT around displayed fireworks not durable	$100.00		7.2.2.3.2.3	Landing LENGTH in direction of travel is less than width.	$100.00
34.832(5)	Customers HANDLING fireworks w/o attendant assistance	$50.00		7.2.2.3.3.1	Horizontal landing not SOLID (i.e. grating or see through)	$100.00
34.832(9)	small quantities of unused BOXES in sales/storage area	$50.00			HANDRAILS	
34.832(11)	EXTENSION CORD located where public can walk over	$50.00		7.2.2.4.4.1	Not 34" to 38" HIGH above leading edge of tread	$100.00
34.832(11)	EXTENSION CORD supplies > one device w/o power strip	$50.00		7.2.2.4.4.5	Less than 2¼" CLEARANCE between rail and wall	$100.00
34.832(11)	EXTENSION CORD unprotected from accidental damage	$50.00		7.2.2.4.4.6	Handrails are not a CIRCULAR cross-section of 1¼" to 2"	$100.00
34.832(11)	EXTENSION CORD used in lieu of fixed structural wiring	$25.00		7.2.2.4.4.7	Rail is not CONTINUOUS	$100.00
34.832(11)	Power STRIP without internal circuit breaker	$25.00		7.2.2.4.4.6	Improper TERMINATION or EXTENSION of rail	$100.00
34.832(13)	Trash CONTAINERS not METAL or heavy plastic	$25.00			GUARD RAILS	
34.832(13)	Trash CONTAINERS < 10ft AWAY from fireworks	$250.00		7.1.8	No GUARD RAIL where egress is > 30" above floor/grade	$100.00
34.832(15)	SPACE HEATER in sales/storage areas	$100.00		7.2.2.4.5.2	Guard RAIL is less than 42" high.	$100.00
34.832(17)	COOKING EQUIPMENT in sales/storage areas	$100.00		7.2.2.4.5.3	Over 4" between any point in VERTICAL RAILS up to 34" high	$100.00
34.817(d)	No 2A EXTINGUISHER per 2,000 sqft & within 75 ft travel	$500.00			RAMPS	
34.817(p)	Internal combustion ENGINES operating inside retail site	$500.00		7.2.5.3.2(1).	No LANDING at top, bottom or at door openings.	$100.00
36.3.3.2	Interior wall and ceiling FINISH is not type Class A or B	$500.00		Tab 7.2.5.2	Single ramp in excess of a 30" RISE.	$100.00
6.1.14.4.1	No FIREWALL -Btwn High Hazard & other occup > 200 sqft	$500.00		Tab 7.2.5.2	SLOPE in excess of 1 in 8	$100.00
	PAPERWORK			Tab 7.2.5.2	Less than 30" WIDE	$100.00
34.817(j)	Original permit not posted in sales area	$100.00		7.2.5.3.1(1)	Not permanent FIXED construction	$100.00
34.817(j)	No permit (site closed until corrected)	$500.00		7.2.5.3.1(4)	Not SOLID construction.	$100.00
34.832(8)	Local FD or County FD not NOTIFIED of location in writing	$100.00		7.2.5.4	No GUARD or HANDRAIL on ramp with rise over 6"	$100.00
34.832(16)	PLAN not on file at SFMO office (site closed until corrected)	$250.00			BULK MERCHANDISING >12,000 sqft	
	FIREWORKS			36.4.5	Violation(s) of Bulk Merchandising requirements	Case
2154.003	Illegal fireworks e.g. Bottle or Pop Rockets, M-80's	$1,000.00			**OTHER NFPA LIFE SAFETY CODE**	
2154.003(b)	ILLEGAL fireworks (Bottle or Pop Rockets, M-80's)	$1,000.00				
2154.251(2)	Sell <100' from storage and dispensing of flammables (closed until corrected)	$500.00		34.832(19)	Violations of NFPA 101 the Life Safety Code®	Case
34.817(o)	Fireworks do not conform to USCPS LABELING	$500.00		9.1.2	One or more FAULTS identified on Receptacle tester	$25.00
34.817(i)	OTHER than fireworks or fireworks promotional items	100.00				